


DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030212001 Purva iela 9 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (131)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.3	Yes
8.0	20.0	13.3	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.3
8.0	13.3

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030213001 Purva iela 7 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (130)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.2	Yes
8.0	20.0	13.2	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.2
8.0	13.2

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030214001 Darza iela 19 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (134)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.2
8.0	13.2

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030215001 Darza iela 17 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (132)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.0	Yes
8.0	20.0	13.0	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.0
8.0	13.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030334001 Darza iela 20A Noise sensitive point: Danish 2019 low frequency - Regular dwellings (135)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.1	Yes
8.0	20.0	13.1	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.1
8.0	13.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030335001 Darza iela 22 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (136)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.1	Yes
8.0	20.0	13.1	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.1
8.0	13.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010030336001 Purva iela 5 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (133)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.1	Yes
8.0	20.0	13.1	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.1
8.0	13.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010040221001 Rigas iela 90 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (142)



Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.3	Yes
8.0	20.0	13.3	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.3
8.0	13.3



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94010040224001 Indranu iela 5 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (143)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.4	Yes
8.0	20.0	13.4	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090006001 Lejas Gerki Noise sensitive point: Danish 2019 low frequency - Regular dwellings (152)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	17.9
8.0	17.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090010001 Liepkalni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (158)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	22.7
8.0	22.7

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090011001 Kalngerki Noise sensitive point: Danish 2019 low frequency - Regular dwellings (147)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	17.7	Yes
8.0	20.0	17.7	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	17.7
8.0	17.7

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090014001 Lukstini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (146)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.8
8.0	15.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090014002 Lukstini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (148)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	16.0
8.0	16.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090023001 Gerki Noise sensitive point: Danish 2019 low frequency - Regular dwellings (154)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	17.9
8.0	17.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090025001 Ausekli Noise sensitive point: Danish 2019 low frequency - Regular dwellings (144)



Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.3	Yes
8.0	20.0	13.3	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.3
8.0	13.3



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090027001 Saulieš i Noise sensitive point: Danish 2019 low frequency - Regular dwellings (151)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.7	Yes
8.0	20.0	13.7	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.7
8.0	13.7

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090028001 Vanagi Noise sensitive point: Danish 2019 low frequency - Regular dwellings (145)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.3
8.0	14.3

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090035001 Dzelzcelš 162. km Noise sensitive point: Danish 2019 low frequency - Regular dwellings (150)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	17.4
8.0	17.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090057001 Pilenieš i Noise sensitive point: Danish 2019 low frequency - Regular dwellings (149)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	18.2
8.0	18.2

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090062001 Kalnstaldoti Noise sensitive point: Danish 2019 low frequency - Regular dwellings (153)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.0	Yes
8.0	20.0	14.0	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.0
8.0	14.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090063001 Jaunzemes Noise sensitive point: Danish 2019 low frequency - Regular dwellings (157)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.9	Yes
8.0	20.0	13.9	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.9
8.0	13.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090104001 Staldoti Noise sensitive point: Danish 2019 low frequency - Regular dwellings (159)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.0
8.0	14.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090120001 Ozolkalni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (160)



Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.0	Yes
8.0	20.0	14.0	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.0
8.0	14.0



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090122001 Jauntilgali Noise sensitive point: Danish 2019 low frequency - Regular dwellings (155)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.9
8.0	15.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880090209001 Gailenes Noise sensitive point: Danish 2019 low frequency - Regular dwellings (156)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.6
8.0	15.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100009001 Oš i Noise sensitive point: Danish 2019 low frequency - Regular dwellings (93)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.6
8.0	14.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100013001 Pinas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (116)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.1
8.0	14.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100013016 Saulites Noise sensitive point: Danish 2019 low frequency - Regular dwellings (100)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.9
8.0	13.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100013018 Gaisini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (115)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.2
8.0	14.2

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100025001 Zemgali Noise sensitive point: Danish 2019 low frequency - Regular dwellings (112)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.1	Yes
8.0	20.0	14.1	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.1
8.0	14.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100029001 Dravas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (94)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.2
8.0	15.2



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100052001 Veverzemnieki Noise sensitive point: Danish 2019 low frequency - Regular dwellings (139)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	18.0	Yes
8.0	20.0	18.0	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	18.0
8.0	18.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100053001 Vecrubeni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (129)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.9
8.0	15.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100053007 Rubeni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (98)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.8
8.0	15.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100096001 Zemdegas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (95)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	15.1	Yes
8.0	20.0	15.1	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.1
8.0	15.1

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100118001 Maja 20 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (122)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.5
8.0	13.5

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100123001 Maja 20 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (141)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.3	Yes
8.0	20.0	14.3	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.3
8.0	14.3

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100148001 Dumini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (99)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	18.8
8.0	18.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100154001 Zveru ferma Noise sensitive point: Danish 2019 low frequency - Regular dwellings (138)



Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.8	Yes
8.0	20.0	14.8	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.8
8.0	14.8



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100169001 Riektini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (125)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.4
8.0	14.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100184001 Sietini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (97)




Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.9	Yes
8.0	20.0	14.9	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.9
8.0	14.9

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100185001 Bajari Noise sensitive point: Danish 2019 low frequency - Regular dwellings (121)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.0
8.0	15.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100186001 Ritass Noise sensitive point: Danish 2019 low frequency - Regular dwellings (96)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.8
8.0	14.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100187001 Zeltini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (111)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.7	Yes
8.0	20.0	14.7	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.7
8.0	14.7

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100188001 Kristali Noise sensitive point: Danish 2019 low frequency - Regular dwellings (118)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.6	Yes
8.0	20.0	14.6	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.6
8.0	14.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100189001 Kastanas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (113)




Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.5	Yes
8.0	20.0	14.5	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.5
8.0	14.5

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100193001 Gravas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (114)



Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	15.0	Yes
8.0	20.0	15.0	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.0
8.0	15.0



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100194001 Noras Noise sensitive point: Danish 2019 low frequency - Regular dwellings (126)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.3
8.0	15.3

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100195001 Viteni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (120)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.2
8.0	15.2

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100196001 Latini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (110)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.8
8.0	14.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100197001 Dzeni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (140)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	14.8	Yes
8.0	20.0	14.8	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	14.8
8.0	14.8

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100199001 Zemites Noise sensitive point: Danish 2019 low frequency - Regular dwellings (119)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	15.0	Yes
8.0	20.0	15.0	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.0
8.0	15.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100213001 Malkalni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (117)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.6	Yes
8.0	20.0	13.6	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.6
8.0	13.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100214001 Lati Noise sensitive point: Danish 2019 low frequency - Regular dwellings (124)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100216001 Rudziš i Noise sensitive point: Danish 2019 low frequency - Regular dwellings (103)



Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.4	Yes
8.0	20.0	13.4	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100217001 Livas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (109)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.7
8.0	13.7

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100218001 Plumes Noise sensitive point: Danish 2019 low frequency - Regular dwellings (123)




Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.6	Yes
8.0	20.0	13.6	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.6
8.0	13.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100219001 Kirš i Noise sensitive point: Danish 2019 low frequency - Regular dwellings (128)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.6
8.0	13.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100220001 Medini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (105)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.6	Yes
8.0	20.0	13.6	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.6
8.0	13.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100221001 Niedras Noise sensitive point: Danish 2019 low frequency - Regular dwellings (101)




Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.5	Yes
8.0	20.0	13.5	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.5
8.0	13.5

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100222001 Taigas Noise sensitive point: Danish 2019 low frequency - Regular dwellings (106)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.5
8.0	13.5

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100228001 Mež vini 2 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (102)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.4	Yes
8.0	20.0	13.4	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100229001 Mež vini 1 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (108)



Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.4	Yes
8.0	20.0	13.4	Yes


Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4



DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100254001 Maja 22 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (107)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.6	Yes
8.0	20.0	13.6	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.6
8.0	13.6

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100255001 Sedaskalni Noise sensitive point: Danish 2019 low frequency - Regular dwellings (137)




Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	16.0
8.0	16.0

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100259001 Seli Maja 18 Noise sensitive point: Danish 2019 low frequency - Regular dwellings (104)




Sound level			
Wind speed	Demands	WTG noise	Demands fulfilled ?
[m/s]	[dB(A)]	[dB(A)]	
6.0	20.0	13.4	Yes
8.0	20.0	13.4	Yes

Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	13.4
8.0	13.4

DECIBEL - Detailed results, graphic

Calculation: Nordex N175-7.0 MW STE Noise calculation model: Danish low frequency 2024  
94880100314001 Vidini Noise sensitive point: Danish 2019 low frequency - Regular dwellings (127)



Calculated noise [dB(A)]

Wind speed	
[m/s]	
6.0	15.0
8.0	15.0